



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

May 24, 2018

National American Corp. LP-Lake Minden
1256 Marcum Road
Nicolaus, CA 95659

Attention: Ronda Barney, Manager

**SUBJECT: NOTICE OF VIOLATION NO. 21-18N-005, PUBLIC WATER SYSTEM NO. 5100117 –
FAILURE TO COLLECT FIVE ROUTINE SAMPLES IN APRIL 2018.**

The California Code of Regulations (CCR), Title 22, Article 3, Section 64424, requires that each public water supplier that collects fewer than five routine samples per month must collect five routine samples the month following a total coliform-positive sample.


Our records show that National American Corp. LP-Lake Minden (hereinafter, System) operates a transient - noncommunity water system and collects one routine bacteriological water quality sample per quarter.

In reviewing our records, we note that the System **did not collect five required routine distribution system samples in the month of April 2018, following a total coliform-positive routine sample in March 2018.**

Failure to collect bacteriological water samples according to the routine sampling protocol the month following a coliform-positive sample is a primary violation of the CCR. This violation would normally require public notification within 30 days and a citation with possible fines.

By sending this letter we are clearly informing you about the routine sampling responsibilities under the CCR. At this time, we do not plan to take formal enforcement action against the System for this violation.

If you have any questions regarding this matter, please call Paul Rowe at (530) 224-4866 or me at (530) 224-4861.


Reese B. Crenshaw, P.E.
Valley District Engineer
DRINKING WATER FIELD
OPERATIONS BRANCH

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

364 Knollcrest Drive, Suite 101, Redding, CA 96002 | www.waterboards.ca.gov